
# Generative Al for Predictive Maintenance

Bhagawan Gnanapa

# **PROCESSES**





**Solar Trackers** 

**String Monitoring** 


Inverters

**Transformers** 


HT/LT Panels

**Power Plant** 

# **GET A QUICK STATUS**



## **Q&A IN NATURAL LANGUAGE**







### **PLANT INFORMATION:**

 Plant Name:
 UVPL Power
 Install Date:
 14-12-2022

 Report #:
 201746565
 Installed/Run Days:
 344

 Report Completed By:
 Admin
 Report Date:
 23-10-2023

 Fault Type:
 Electrical Overload

### **NOTES**

The inverter has detected an electrical overload and has shut down.

### **CAUSE OF FAILURE**

### **CLASSIFICATION: H**

Despite advanced protections, electrical overload can still occur if there's a sudden surge in power from the solar array, possibly due to faults in individual panels or a failure in the MPPT process.

### **RECOMMENDATIONS**

- Isolate and inspect the solar panel array to identify faulty panels or wiring.
- Ensure that the inverter's MPPT algorithms are tuned to respond rapidly to changing conditions.

### **Reports Insights**

×

From the provided inverter data and alarm status, here are the key points: 1. Auxilary Input4 and Input5 failed and then recovered. 2. Auxilary Input6 and Input7 encountered failures. However, they also recovered. 3. An emergency stop was initiated but was later recovered. 4. Inverter Fuse and Fan Contactor experienced failures but they are now OK. 5. PCS was in Stop and Standby modes. 6. Issues were encountered with IGBT Heatsink Temperature, Gate Drive Power Supply, Relay IO Card Comm, and Keypad Card Comm, but they were all recovered. 7. There was a Precharge failure, which has been recovered. 8. Alarms were triggered due to 6C Off Failure, AC CB Off Fail, DC CB Off Fail, and Surge Suppressor Fail. All these issues are now recovered. 9. There were also failures due to wrong operation and ambient temperature, however, the document does not specify their current status. 10. There were some incidents of abnormal stop, which have been reset. Also, the AC Output Contactor has been switched on and off. 11. The inverter data also recorded some incidents such as Emergency Stop, External System Abnormal, Fan Contactor, Feedback Abnormal, Frequency High/Low, Gate Drive Power Supply, IGBT Heat Sink Over Temperature, and IGBT Sat Trip. Please note that some parts of the data are cut off, and complete recovery or the current status of some systems could not be confirmed.

How can I help you today?



