




Imagination is more important than knowledge - Albert Einstein

Resilient Affordable Decarbonized Energy (RADE) for Data Center (DC) - **alternate prime movers** for Combined Heat & Power (CHP)



April 2026

Suresh Jambunathan
Principal, Energy and Water Development LLC ("EnWaDev")
630-335-4544
suresh.Jambunathan@enwadev.com



GOALS: Behind-the-meter resilient affordable decarbonized energy (RADE) for Data Center.

WHAT is the problem?:

Data Centers need energy – power & chilling. Traditional grid based power is expensive & slow to deploy.

HOW & WHY can we offer an alternative?




- Behind-the-meter, natural gas Combined Heat & Power (CHP) can be configured using microturbines (MT), fuel cells (FC) or conventional gas turbines (GT) with waste heat to absorption chillers.
- Each CHP configuration has characteristics –
 - CapEx, OpEx,
 - emissions, noise, vibrations,
 - energy density, technology maturity, availability, scalability, modularity,
 - fuel-to-power efficiency (aka heat rate), part load efficiency,
 - nature of waste heat (exhaust, hot water),
 - ramp rate etc...
 - Delivery schedule

PROJECT DEVELOPMENT:

- conceptual design > Limited Notice to Proceed (LNTP)
- basic engineering > Final Notice to Proceed (FNTP)
- detailed engineering & equipment procurement
- site construction > start-up





Data Center (DC): a set of 24/7/365 computers supported by electrically intensive support equipment



- Need (20-60 KW/rack) of high-quality, reliable power; more if AI-centric DC
- Use 1.5% of global electricity and responsible for 1.0% of global GHG emissions; both figures are increasing
- Need reliable (99.9999% available), high quality (steady voltage, frequency) power
- Use grid power with UPS and diesel gensets for backup. Non-core capital parked-in-place
- Need expensive cooling to remove resistive heat (I^2R) from site computers; electric chillers are default cooling solution.
- Significant non-IT power electric loads require capital for non-IT power assets and parasitic power expense



What is Combined Heat & Power (CHP)? 1-input and 2 or more outputs




Unlike intermittent & variable renewables, CHP systems efficient generate on-demand energy in electrical and thermal form with low GHG footprint

Regular power plants generate power by burning fuel, but waste heat; hence net-net increase pollution.




CHP complements DC to cut cost *and* minimize GHG emissions. Waste heat to Absorption Chilling (AC) saves Elec. Chlr CapEx, OpEx

GRID POWER: *less efficient, more cost, more GHG emissions*



CHP ENERGY: *more efficient, less cost, less GHG emissions*



ENERGY DELIVERY APPROACH	GHG Emissions	Efficiency	Investment	Optg. Cost
GRID power, backup generator, UPS	MORE	LESS	MORE	MORE
CHP configured with VAC	LESS	MORE	LESS	LESS

CHP waste heat *via* a bolt-on Vapor Absorption Chiller (VAC) produces chilled water that displaces chilled water from conventional electric chiller.

IMPORTANT: in a real-world system, an optimized CHP system incorporates “free-cooling” plus energy storage (*Battery Energy Storage System, BESS and thermal energy chilled water*) plus small electric chiller for “trim” chilling etc plus retain existing site grid tie-in.



Total Invested Capital (\$TIC) of onsite CHP-VAC microgrid <= traditional energy supply (all grid power, ECC, diesel genset etc...)

	Energy Supply Configuration	CHP+VAC	versus	Traditional
	PROJECT INVESTMENT SCAFFOLD	A		B
A	DIRECT: EQUIPMENT			
	multiple Nat. Gas generators (MT/GT/FC/RICE)	\$\$\$\$		-
	Vapor Absorption Chillers (VAC)	\$		-
	Electric Centrifugal Chillers (ECC)	-		\$\$
	multiple Diesel gensets sized to DC capacity	-		\$\$\$
	Cooling Tower (wet/dry / hybrid)	\$		\$
	raw water treatment system	\$		\$
	grid power feed and/or sub-station upgrade	-		\$\$\$
	Power conditioning: BESS/UPS	\$\$		\$\$
B	BALANCE OF PLANT (BOP)			
	geotechnical / site grading	\$		\$
	Civil/structural	\$		\$
	Mechanical - pipe, duct etc..	\$		\$
	Electrical: ATS, switchgear, Distribution Panel etc...	\$		\$
	Instrumentation & Control	\$		\$
C	INDIRECT / "SOFT COSTS"			
	Engineering	\$		\$
	Project & Construction Management (PM/ / CM)	\$		\$
	staff mobilization & administrative compliance	\$		\$
	Permits: air, water, trade, construction & operating	\$		\$
	taxes / fees / duties	\$		\$
	equipment transport to site	\$		\$
	legal - contracts	\$		\$
	finance	\$		\$
	development fee	\$		\$
	capitalized working capital	\$		\$
	other	\$		\$
D	CONTINGENCY	\$\$		\$\$\$
E=A+B+C+D	PROJECT INVESTMENT	\$\$\$		\$\$\$\$


CapEx savings drivers for CHP+VAC configuration vs. traditional:

1. Reduced equipment costs
2. Shorter / more controllable delivery schedule
3. CHP CapEx grant from local utility



Select prime mover choices – leading CHP prime movers have distinct performance characteristics

Small Microturbine (MT) Gas Turbine (GT)



Capstone C200/C1000

- ⚡ 30 kW – 1,000 kW per unit (scalable to 30 MW)
- ☀ Single moving part, air bearings, compact footprint
- 📍 Ideal for distributed CHP, district energy, and behind-the-meter applications

Titan™ 130 Generator Set Performance			
ISO Continuous Duty Output	Heat Rate	Exhaust Flow	Exhaust Temperature
14,000 kW	10,405 kJ/kWh 9320 Btu/kWh	179,000 kg/hr 394,750 lb/hr	420°C 792°F


Mars® 100 Generator Set Performance			
ISO Continuous Duty Output	Heat Rate	Exhaust Flow	Exhaust Temperature
10,500 kW	11,090 kJ/kWh 10,000 Btu/kWh	160,300 kg/hr 353,590 lb/hr	485°C 900°F

Mars 90 Generator Set Performance			
ISO Continuous Duty Output	Heat Rate	Exhaust Flow	Exhaust Temperature
9450 kW	11,300 kJ/kWh 10,710 Btu/kWh	144,590 kg/hr 318,760 lb/hr	470°C 870°F

Eg: Solar C50, T60-65-70, T130,250 etc...

- ⚡ 5 MW – 70+ MW per unit
- ✈ Aircraft-engine heritage, fast start (5–10 min), high cycling capability
- 📍 Suited for utility-scale CHP and industrial cogeneration

Fuel Cell (SOFC, molten carbonate)



Eg: Fuel Cell Energy, / HyAxiom / Bloom etc...


- ⚡ 200 kW – 2500 KW (modular)
- 🕒 Electrochemical conversion, no combustion, near-silent operation
- 📍 Best for premium power, data centers, and zero-emission mandates



Key equipment: Vapor Absorption chiller available as modular, factor built, skid-mounted units ==> reduced risk



G A Drawing




NOZZLE SCHEDULE		
NOZZLE	NOZZLE FL. RATING	DESCRIPTION
N1	ASA 150	CHILLED WATER INLET
N2	ASA 150	CHILLED WATER OUTLET
N3	-	CHILLED WATER DRAIN PLUGGED
N4	ASA 150	COOLING WATER INLET
N5	ASA 150	COOLING WATER OUTLET
N6	-	COOLING WATER DRAIN PLUGGED
N7	ASA 150	STEAM INLET
N8	ASA 150	CONDENSATE OUTLET
N9	ASA 150	RUPTURE DISK OUTLET

NOTES :

- 1) ♦ INDICATES THE POSITION OF ANCHOR BOLTS.
- 2) † INDICATES THE POSITION OF THE POWER SUPPLY CONNECTION ON CONTROL PANEL.
- 3) MINIMUM INSTALLATION CLEARANCE.
CONTROL PANEL SIDE :50"
TOP : 10"
OTHERS : 20"
- 4) MACHINE TOLERANCES :

L (INCH)	TOL. (INCH)
0-100	0.2
100-200	0.3
200-300	0.4
300-400	0.5
OVER 400	0.7

- 5) RUPTURE DISK OUTLET IS TO BE PIPED OUT ACCORDING TO THE LOCAL RULES AND REGULATIONS. MAXIMUM PIPING ELEVATION SHALL NOT EXCEED THE HEIGHT OF M/C.





Select CHP prime movers: more technical + economics considerations

INPUT	UNIT	VALUE	COMMENT	
Deliv. Nat. gas	\$/MMBtu, HHV	\$4.0	assumed	
CHP Chilling Required	TonsR/MW _e	284	thermodynamics	
PARAMETER	UNIT	MICROTURBINE	GAS TURBINE	FUEL CELL
Electrical efficiency	%LHV	30.0%	33.0%	48.0%
Heat rate	LHV Btu/KWh	11,377	10,342	7,110
Available Waste Heat	Btu/KWh	7,964	6,929	3,697
COP of VAC unit		1.30	1.30	0.90
Chilling delivered	TonsR/MW _e	431	375	139
CHP-VAC chilling adequate?		yes	yes	no
CHP VAC chilling deficit	TonsR/MW _e	0	0	(145)
Accept opportunistic grid power?		yes	yes	no
NOISE		quiet	high	ultra-quiet
VIBRATION		very low	medium	approx. zero
STACK: AIR EMISSIONS				
NOx, CO, UHC/VOC, PM		very low	low	ultra-low
Emissions Control reqd?		usually no	sometimes	No
Nominal availability	%	97%	96%	95%
Nominal availability	full-load hrs/yr	8,497	8,410	8,322
Ramp rate	% full load/min	35%	35%	5%
Part-load performance: efficiency		poor	poor	acceptable
22 MW CHP SYSTEM- INSTALLED ROM ECONOMICS:				
CapEx - before incentives	\$/KWe	\$4,500	\$4,000	\$6,000
CapEx - before incentives	\$MM	\$99	\$88	\$132
Fuel Cost of Power (FCP)	\$/MWh	\$50.0	\$45.5	\$31.3
NON-FUEL OpEx	\$/MWh	\$25.0	\$20.0	\$30.0
Sub-total: FCP + NF OpEx	\$/MWh	\$75.0	\$65.5	\$61.3
Fuel Cost of Power (FCP)	c/KWh	5.0	4.5	3.1
NON-FUEL OpEx	c/KWh	2.5	2.0	3.0
Sub-total: FCP + NF OpEx	c/KWh	7.5	6.5	6.1
Delivery: PO to site	months	8-to-10	12-to-24	10-to-15
INCENTIVES:				
Investment Tax Credit		no	no	yes
Bonus depreciation		yes	yes	yes
New Market Tax Credit (NMTC)		location dependant	location dependant	location dependant
Local utility (elec, gas) grants		site specific	site specific	site specific

CHP configured with VAC influenced by factors as tabulated

ENERGY FACTS & EQUIVALENCES:

1-KWh = 3413 Btu *quantity*

1-MWh = 3,413,000 Btu *quantity*

1 MW = 3413,000 Btu/hr *rate*

1-TonR = 12000 Btu/hr *rate*

hence:

1 MW = 284 TonsR *rate*




Phase 1 concept: modular CHP configured as gas turbine and exhaust waste heat to absorption chilling. Energy (power, chilling) to data center

3rd

01-25-2026

Enwadev NG CHP as MT + VAC Plus water treatment system (WTP)



OBSERVATIONS

- + CHP configured as 15-MT + 15 VAC.
- + Common NG feed headers chilled water and condensate water to/from each VAC
- + A set of 5-MT + 5-VAC tied to a cooling tower. Hence 3-CT's total.

Raw water treatment system.

Enwadev CONFIDENTIAL

Suresh.T.



Phase 1 CHP sized per available Nat. gas: modular parallel units with common supply / return lines. Easy constructability=reduced scope creep risk


3rd
01-25-2026 Enwadev NG CHP as 15x(MT+VAC)

In Nat Gas: 170 mmbtu/hr
makeup H₂O: 270 gpm @ 100 mgpy.

OUT Power: 15 MW
chilling: 6000 Tons R

MT dimensions
L = 360"
W = 96"
H = 136"
weight dry = 59,000 lbs

VAC dimensions
L = 225"
W = 145"
H = 144"
weight dry = 40,000 lbs




Enwadev Business Confidential

Suresh J.

to data center



Technical basics 1: Process Flow Diagram + Heat Mass Balance (PFD+HMB) for CHP+VAC + assumed available grid power



IMPORTANT: CHP+VAC provides option for hot water district heating loop using available medium-grade waste heat exiting Vapor Absorption Chiller (VAC).

Overall system efficiency, % HHV:

- CHP+VAC only: ~ 70%
- CHP+VAC + hot water heat ~ 85%



Select risks & mitigants. Project success = managing risk

RISKS	MITIGANTS
Variance from	
CapEx estimate	scope freeze = <i>avoid</i> scope creep. Immediate permits line-of-sight. Quickly execute key contracts, make down payments to secure production slot, parall site preparation
OpEx estimate	Execute Equipment Agreements, hire key staff, share select resources with city
Fuel reqd. estimate	Equipment performance ("heat rate") guarantees at design & off-design conditions
design / process performance	1st principles heat & mass balance; pass-thru equipment performance guarantees
Permit delays	Concept scope freeze, immediately engage permit authorities for permit <i>line-of-sight</i>
Spark-spread Ratio (SSR) squeeze.	unlikely - local and ISO grid is heavily gas marginal
Gas supply	Uninterruptible supply contract, onsite fuel storage ("CNG bullets"), virtual gas pipeline
Grid power supply	grid connect exists & desirable as backup. But..... grid power not required. CHP can be 100% nat. gas fueled
Tariff / taxes / duties	continually update CapEx estimate; maintain healthy contingency
Engineering delays	freeze conceptual design; rapidly advance to engineering
Construction delays	scope freeze > rapid engg. Deliverables to construction contractor. Payments tied to milestone completions; insurance and/or bonding



Tradeoffs: Cost Vs. Accuracy Vs. Time

ESTIMATE CLASS	ESTIMATE TYPE	PURPOSE	ACCURACY	PROJECT COMPLETION	COST & TIME
5	Order of Magnitude (OOM)	Initial Feasibility or screening	-50% to 100%	0%-to-1%	Free-to-\$10,000 2-hours-to-3 days
4	Preliminary	Concept study or feasibility	-15% to 50%	1%-to-15%	\$5,000-to-\$50,000 2-days-to-5 weeks
3	Definitive	Budget, authorization or control	-10% to 30%	10%-to-40%	3%-to-5% of final CapEx 4-weeks-to-4 months
2	Detailed	Control or bid/tender	-5% to 20%	30%-to-70%	4%-to-10% of final CapEx 2-to-6 months
1	Check (Construction)	Bid/tender	-3% to 15%	50%-to-100%	5%-to-20% of final CapEx 3-to-12 months



FRONT END LOADING (FEL) & PROJECT DEVELOPMENT

FEL STAGE	FEL1: Business Assessment	FEL2: Alternatives Selection. <i>Conceptual Engineering</i>	FEL3: Scope Definition. <i>Basic Engineering</i>	FEL4: Engineering, Procurement & Construction Management (EPCM). <i>Detailed Engineering+</i>	FEL5: Commissioning & Operations & Evaluation
PURPOSE	Identify projects aligned with business objectives	Select preferred process & technology options	Complete scope definition: validate business premises, ensure project execution with a degree of certainty	Implement Project Execution Plan (PEP)	Meet design nameplate; evaluate against business objectives
OBJECTIVES	Define business premises Define project objectives List assumptions - technical & commercial Identify risks & state mitigants Preliminary economics Justify & prioritize projects	Validate business premises Analyze alternate process & technology options; select best alternative Develop Process scope of work Process Flow Diagram with Heat & Mass Balance (PFD + HMB) Utilities availability ("gap analysis") Identify uncertainties & risks	Finalize scope of work, schedule and cost Value engineering for cost reduction Mitigation of risks & uncertainties Project Execution Plan (PEP) Gather project team Secure project funding	Complete Detailed Engineering Secure required permits Create equipment procurement plan Mobilize construction resources - project / construction manager, prime contractor & sub-contractors EHS management Checkout & commissioning	Achieve nameplate production
DELIVERABLES	FEL 1 deliverables check list Abstract / objectives statement Resource assignment Project manager Project Engineer Other CapEx: Order of magnitude. ± 50% O&M, G&A: Order of magnitude. ± 50% FEL2 plan with milestone schedule	FEL 2 deliverables check list Basic economic model PFD + HMB, basic plot plan Permitting requirements & strategy O&M strategy EHS requirements & strategy Technical risk assessment Major equipment list and key vendors CapEx: Conceptual estimate +35% -20% O&M, G&A: conceptual estimate. ± 25% FEL3 plan with milestone schedule	FEL 3 deliverables check list Major equipment list & specifications with firm quotes Finalize plot plan Issue for design: P&ID, control lists, electrical 1-line diagrams Conduct HAZOP review EHS requirements & strategy Project Execution Plan (PEP) with Work BreakDown Structure (WBS) & sub-contracting plan CapEx: quasi-investment grade estimate +15% -5% O&M, G&A: estimate ± 15% Detailed construction schedule	Commissioned project Purchase & receive equipment & bulk materials, manage construction to support PEP Manage change orders Final HAZOP review	Collect operating data Capture formal lessons learned Capture process improvements for future projects Prepare for project close-out
COSTS	\$1,000 <= co\$t <=\$5,000	0.3% <= \$ TIC <= 1.0%	0.7% <= \$ TIC <= 3.0%	3.0% <= \$ Engineering <= 15.0% rest for Procurement & construction	Funded from O&M,G&A budget
FUNDING SOURCE	Owner expensed	Owner expensed	Owner expensed or capitalized	Capitalized	
DURATION	1 <= days <=5	2 <= weeks <=12	6 <= weeks <=18	6 <= months <=24	
GLOSSARY	O&M, GA Operations & maintenance, General & Administrative PFD+ HMB Process Flow Diagram + Heat & Mass Balance		TIC HAZOP	Total Installed Cost Hazard & Operability Analysis	



APPENDIX





Questions?

Suresh Jambunathan
Principal, Energy and Water Development LLC (“EnWaDev”)
630-335-4544
suresh.Jambunathan@enwadev.com



Who is Energy & Water Development LLC (“EnWaDev”)

Assertions:

1. Efficiency *hedges* energy & water price volatility.
2. *Profitably* reduce Greenhouse Gas Emissions.
3. *No conflict* between your wallet and your conscience.



Suresh Jambunathan ✓

Owner/Principal at Energy and Water Development, LLC (EnWaDev)

Aurora, Illinois, United States · [Contact info](#)

4,016 followers · 500+ connections

A. Consulting:

Energy & Water optimization strategy (“Demand Reduction”, then “Supply Optimization”) Investment grade financial analysis encompassing concept development, project structuring, contracting strategy, technology assessments, bid management, environmental impact, project schedule and constructability etc...

B. Development:

Design-Build and Own projects. Deliver as full-wrap Engineering Procurement & Construction (EPC) or part-wrap Engineering, Procurement & Construction Management (EPCM).

C. Operations & Maintenance:

Reliable energy & water to the customer and maintain asset value for the owner

Preferred partnerships with equity funding group, design-engineering-construction group plus O&M support team



ASSUMPTIONS: gas turbine CHP+VAC sized to currently available natural gas: waste heat recycled into Vapor Absorption Chilling (VAC)

INPUT	INPUTS IN BLUE	UNIT	VALUE	COMMENT
OPERATING ECONOMICS: Delivered cost of				\$K in yr1 c/KWh, yr1
Grid power	use spare CHP VAC chilling	cents/KWh	14.0	\$7,656 14.3
Fuel & Water EXPENSE				\$K c/KWh
Natural gas		\$/MMBtu HHV	\$4.00	\$7,427 4.71
Reclaimed water - Cooling Tower		\$/Mgal	\$0.00	\$0 0.00
City water - Cooling Tower		\$/Mgal	\$8.00	\$985 0.62
O&M SG&A EXPENSE				
Eqp. Maintenance: Long Term Service Agreement (L TSA)				
C1000 Microturbine (MT)	CHP gen. pwr	cents/KWh	1.5	\$2,461 1.56
VAPOR ABSORPTION CHILLER (VAC)		cents/Ton-hr	1.0	\$651 0.41
HYBRID: Wet Surface Air Cooler (WSAC)		\$/MMBtu	\$0.25	\$346 0.22
FUTURE: Hot Water Boiler (HWB)		\$/MMBtu	\$0.00	\$0 0.00
Staff: (Mgr, Ops, Maint. Admin etc...)	CHP gen. pwr	cents/KWh	1.0	\$1,641 1.04
Consumables & miscellaneous	CHP gen. pwr	cents/KWh	0.3	\$492 0.31
			\$14,002	8.88



CHP only, year 1 = full operation

INPUT to CHP	UNIT	PEAK	UNIT	ANNUAL
Natural Gas	MMBtu/hr	204	MMCF/yr	1,741
makeup water to Clg. Twr	gpm	359	MMGal/yr	121
Grid power	MW _e	6.0	MWh/yr	52,560
OUTPUT to Data Center	UNIT	PEAK	UNIT	ANNUAL
Chilled water	TonsR	7,142	MMTon.hr/yr	62.6
Net CHP Power	MW _e	16.5	MWh/yr	144,871
Grid power	MW _e	6.0	MWh/yr	52,560
NET Power to DC	MW_e	22.5	MWh/yr	197,431

OUTPUT	UNIT	VALUE
Efficiency: CHP + VAC only	%HHV	70%
Efficiency: CHP-VAC + future Hot Water	%HHV	88%
Power Usage Effectiveness (PUE) and Data Center Infrastructure Efficiency (DCiE)		
A. Power: IT Equipment = net CHP power + grid power	KW _e	22,538
B. Power: full site = gross CHP power + grid power	KW _e	24,000
B/A: PUE		1.06
A/B	DGE	94%

INPUT	INPUTS IN BLUE	UNIT	VALUE	COMMENT
CHP-VAC stack emissions				
NOx		lb NOx/MMBtu HHV	0.0362	C1000
CO		lb CO/MMBtu HHV	0.0247	C1000
UHC		lb UHC/MMBtu HHV	0.0097	C1000
VOC		lb VOC/MMBtu HHV	0.0097	C1000
PM ₁₀ /PM _{2.5}		lb PMx/MMBtu HHV	0.0009	C1000
GHG Emissions				
CO2: Nat. Gas combustion		lb CO ₂ /MMBtu HHV	117	stoichiometric
CO2: marginal grid emissions		lb CO ₂ /MWh	1,100	https://www.epa.gov/avert/avert-web-

OUTPUT	VALUE	VALUE
CHP-VAC stack emissions		
	pph	mt/yr
NOx	7.4	29
CO	5.0	20
UHC	2.0	8
VOC	2.0	8
PM10/PM2.5	0.2	1
GHG Emissions		
CO2: Nat. Gas combustion	23,837	94,915
CO2: marginal grid emissions	6,600	26,280
TOTAL Project related emissions	30,437	121,195

IMPORTANT: Optimized CHP system incorporates “free-cooling” plus energy storage (Battery Energy Storage System, BESS and/or UPS plus retain existing site grid tie-in.



Technical-financial 1: OpEx + primary fuel savings of CHP-VAC *versus* traditional energy supply (*power, chilling*) for nominal 22.5MW data center

O&M, SGA plus primary fuel (*gas, grid power*) savings are drivers for CHP+VAC vs. traditional configuration.

1. On an energy-normalized basis, **\$Natural Gas: \$4/MMBtu <<<< Grid power: 14 c/KWh = \$41/MMBtu**

2. CHP+VAC more efficient than traditional configuration; PUE manifests efficiency advantage.

3. **OpEx + fuel savings ~\$20 MM/yr of CHP+VAC Vs. traditional config. pays for CapEx investment.**

4. CHP+VAC CapEx estimate is work-in-progress. Needs scope and sizing *freeze* to tighten current Total Installed Cost (\$TIC) guesstimate \$75-to-\$85 MM.

Net power to Data Center (DC)		MW _e	22.5	22.5
Configuration			C1000 Microturbine (MT)	Elec. Centr. Chlr
Configuration			VAPOR ABSORPTION CHILLER (VAC)	b/u diesel genset
Configuration			Grid pwr spare chlg. Cap.	All grid power
Configuration			CHP+VAC	traditional
PARAMETER	UNIT	A	B	
Net CHP Power	MW _e	16.5	-	
Grid power	MW _e	6.0	22.5	
parasitics (ECC, pumps etc..)	MW _e	1.5	6.6	
Site gross power	MW_e	24.0	29.1	
PUE		1.06	1.29	
Natural Gas	MMCF/yr	1,741	-	
Diesel	gal/yr	-	42,867	
Reclaimed water - Cooling Tower	MMGal/yr	0	0	
City water - Cooling Tower	MMGal/yr	121	78	
makeup water to Clg. Twr	MMGal/yr	121	78	
OPERATING ECONOMICS: Delivered cost of				
grid power	\$K	\$7,656	\$37,166	
natural gas	\$K	\$7,427	-	
diesel	\$K	-	\$129	
Reclaimed water - Cooling Tower	\$K	\$0	\$0	
City water - Cooling Tower	\$K	\$985	\$640	
O&M SG&A EXPENSE				
Eqp. Maintenance: Long Term Service Agreement (LTSA)				
C1000 Microturbine (MT)	\$K	\$2,461	-	
VAPOR ABSORPTION CHILLER (VAC)	\$K	\$651	-	
HYBRID: Wet Surface Air Cooler (WSAC)	\$K	\$346	\$346	
Electric Centrifugal Chiller (ECC)	\$K	-	\$976	
Diesel backup gensets	\$K	-	\$291	
FUTURE: Hot Water Boiler (HWP)	\$K	-	-	
Staff: (Mgr, Ops, Maint. Admin etc...)	\$K	\$1,641	\$1,641	
Consumables & miscellaneous	\$K	\$492	\$492	
TOTAL Fuel + O&MSG A EXPENSE	\$K	\$21,657	\$41,680	
TOTAL Fuel + O&MSG A EXPENSE	cents/KWh_{to DC}	11.0	21.1	

EXCLUDES Capital recovery. Total Invested Capital: \$TIC A <= \$TIC B



Effective Project Development Contract

Decide Commercial structure based on simple contracts, open book costing & equal alignment of interests

- Commercial Operations Date (COD)
- Milestones – Engineering completed, issue PO's for equipment, start construction, Equipment delivery, start commissioning
- Commercial: EPC or EPCM, rates, cost caps, profit percentage, other
- Performance guarantees for generator heat rate, VAC perf. (TonsR), availability etc...
- Warranties – part load performance, perf. Degradation, outage rates, component costs
- Acceptance criteria
- Bonus or penalties for over / under performance
- Project Execution Plan and critical path to completion



OTHER benefits of CHP-VAC versus grid power only

- Superior energy supply resiliency = *Redundancy + Availability*
- CHP systems are scalable; i.e. modular, skid-mounted and easy delivery to site
- Simple tie-ins for fuel, chilled water and power
- Reduce stranded asset risk; dis-connect and move modular CHP systems if needed
- Predictable data center load is a perfect fit to CHP; several avenues to optimize
- If possible, the project can
 - monetize value of superior energy supply resiliency
 - monetize GHG emissions
- Stand-alone nature of CHP assets lends itself to non-recourse project financing
- Data Center (DC) developer can avoid investing in critical, but non-core energy supply; instead redirect all available capital into the DC

Project planning

Set objectives & gather data

Conceptualize configurations + appraise economics

Project development

Technical: Configuration, Engg; Procurement, Constr.


Legal: Structure (LLC, S or C Corp etc...)

Commercial: Contracts for fuel, power/steam, O&M

Environmental: Permits

Financial: Financial models, equity & debt

Risks & Mitigants: Project Execution Plan (PEP)






Alternate Energy supply project financing models

ECONOMIC MODEL	DESCRIPTION
Energy as a Service (EaaS)	The EaaS provider delivers energy (heat, cool) <i>up to limit of customer needs</i> . The EaaS provider takes Finances-Designs-Builds-Owns-Operates-Maintains (FDBOOM) the HP assets per a long term Energy Services Agreement (ESA) typically comprising a monthly capacity payment <i>plus</i> pass-thru variable charge indexed to cost of power, consumables etc...
Energy Service Performance Contract (ESPC)	Energy Service Company (ESCO) will FDBOOM the project and share savings or provide guaranteed energy savings
Pay for Performance	Customer pays a fixed rental fee for HP equipment based onn actual energy saved
Conventional equipment lease	The HP is leased to the energy customer over a pre-determined lease term. At end of lease term, the HP asset can be returned or the lease is renewed or customer can opt to buy asset at a negotiated cost
Property Assessed Clean Energy (PACE) financing	The HP assts is financed by a long-timer, lower cost loan issued by a bank / financing source. Repayments are an add-on charge to property tax bill, thus enabling easier transfer of the site to new owners.

Think *thrice*, prelim.-design *twice*, detail design-construct *once*

DELIVERABLES

OVERALL PROJECT COMPLETION PERCENTAGE VS. COST INFLUENCE CURVE






Project Execution Plan (PEP) for schedule-budget-resource expectations





Financials: simple payback or IRR? Empirically related





Indicative performance: thermodynamics, GHG emissions and economics: GT and RE based CHP-VAC *versus* grid power

INPUT	INPUTS in BLUE	UNIT	VALUE	COMMENT	OUTPUT	UNIT	VALUE	COMMENT
Data Center loads (servers etc..)		MW _e	25	assumed	Elec. Chlr to cool servers	MW _e	5.0	calculated
Efficiency of offset Elec chiller		KW _e /TonR	0.70	typical	Servers cooling Load	TonsR	7,110	calculated
Delivered Grid power		cents/KWh	10.0	assumed				
Delivered Natural Gas		\$/MMBtu, HHV	\$3.00	assumed	DATA CENTER: Peak LOAD	MW_e	30.0	\$26.3 MM/yr
CHP system Req'd. Payback		years	8.0	assumed	Data Center Grid electricity req'd	MWh/yr	262,601	calculated
GHG emissions								
CO ₂ from Grid power		Lb CO ₂ /MWh	1,200	site specific; eGRID				
CO ₂ from Nat. Gas combustion		Lb CO ₂ /MMBtu	116.0	stoichiometry				

PARAMETER	INPUTS in BLUE	UNIT	CHP-VAC SYSTEM	
			GT-CHP	RE-CHP
CHP generator capacity		MW _e	22.7	25.5
Generator Heat Rate		HHV Btu/KWh	10,497	8,600
CHP Fuel req'd.		HHV MMBtu/Hr	238	220
CHP-VAC sizing		TonsR/KW _{gen}	0.46	0.25
VAC size		TonsR	10,439	6,383
CHP SYSTEM EFFICIENCY		% HHV	82%	75%
Elec. Chlr offset by VAC		MW _e	7.3	4.5
CHP supply to Data Center load		MW_e	30.0	30.0
Does CHP meet DATA CENTER LOAD?			YES	YES
OpEx (Gen + VAC)		\$/MWh	\$13	\$22
CHP Prime mover		\$/KW _e	\$700	\$700
CHP VAC		\$/TonR	\$1,100	\$900
CHP Prime mover		\$MM	\$15.9	\$17.9
CHP VAC		\$MM	\$11.5	\$5.7
CHP - Bal of Plant		\$MM	\$24.6	\$23.6
CHP INVESTMENT		\$MM	\$52.0	\$47.2

PARAMETER	INPUTS in BLUE	UNIT	CHP-VAC SYSTEM	
			GT-CHP	RE-CHP
OVER-SIMPLIFIED ECONOMICS (assumes 8760 hrs/yr)				
OpEx		\$MM/yr	\$2.6	\$4.9
CapEx recovery		\$MM/yr	\$6.5	\$5.9
Fuel		\$MM/yr	\$6.3	\$5.8
TOTAL CHP-VAC EXPENSE		\$MM/yr	\$15.3	\$16.6
TOTAL CHP-VAC EXPENSE		cents/KWh	5.8	6.3
DIRECT SAVINGS		\$MM/yr	\$10.9	\$9.7
<i>versus</i>		cents/KWh	4.2	3.7
Grid Power		% saved	42%	37%
Additional CapEx saved - electric chiller, diesel genset, UPS systems etc..				
CHP Grid power offset				
Generator		MWh/yr	198,790	223,660
VAC offset elec. Chlr		MWh/yr	64,010	39,140
TOTAL		MWh/yr	262,800	262,800
GHG emissions				
offset CO ₂ from Grid power		met.tonne/yr	(143,345)	(143,345)
CO ₂ from Nat. Gas combustion		met.tonne/yr	110,028	101,419
NET change GHG emissions		met.tonne/yr	(33,317)	(41,926)
NET change GHG emissions		% decrease	-23%	-29%