




**AMERICAN
POWERSYSTEMS**

**Advancements in DC Shock and Arc Flash Coming to
NFPA 70E and IEEE 1584 in the Future
Based on Real-World Testing**

Effects of Current Through the Body (time-dependent)


Effect	AC mA	DC mA
Tingling Sensation Perceptible	1/10 - 1/2	1 - 2
Involuntary Reflex (Let-go current)	1/2 - 5	2 - 30
Possible Tetany (Unable to Let-go)	5 - 400	30 - 200
Possible Respiratory Arrest (Paralyzed Diaphragm)	30 - 200	170 - 200
Ventricular Fibrillation	50 - 200	200 - 500
Heart Failure	500+	500+
Internal Organs Burn	1500+	1500+



Current Through the Body Calculation


- equivalent human Body Resistance Varies Greatly
 - Average Human Dry Skin $R \approx 20,000 \Omega$
 - Average Human Wet Skin $R \approx 1,250 \Omega$
 - Human Sweaty Skin R as low as 500Ω (Worst-Case w/o Wounds?)
 - Also Varies Arm-to-Arm vs Arm-to-Foot
 - Worst Cases for the Heart are Arm-to-Arm or Left Arm - Foot
- Sample Calculations:
 - 120 VAC rms
 - Dry Skin: $I \approx 6 \text{ mA}$ (tingle & let-go)
 - Wet Skin: $I \approx 100 \text{ mA}$ (might be deadly)
 - 240 VDC
 - Dry Skin: $I \approx 12 \text{ mA}$ (tingle & let-go)
 - Wet Skin: $I \approx 190 \text{ mA}$ (hard to let go)

Ohm's Law



Shock and Arc-Flash/Blast Boundaries

- Restricted Approach Boundary: Shock Protection Required
 - Reserved for Qualified Persons Only
- Limited Approach Boundary: Qualified vs Unqualified/Escorted
- Arc Flash Boundary: Arc Flash Protection Required
 - Distance at Which Incident Energy Causes 2nd-Degree Burn (1.2 cal/cm²)



DC Shock Risk Table

- Determine the Boundaries from Table 16 of the Safety Policy
 - Tables Derived From NFPA 70E-2021 Article 130

This will be going back
to 100 VDC
in NFPA 70E-2024

System Voltage	Limited Approach Boundary for Exposed Fixed Circuit Part	Restricted Approach Boundary
0 → 50 V (12, 24, 48 VDC)	not specified	
51 – 300 V (125, 250 VDC)	3'6"	Avoid Contact
301 – 1,000 VDC (med-large UPS)		1'

Arc-Flash PPE Categories (From NFPA 70E Article 130)

- Arc Flash Boundary:
 $\leq 1.2 \text{ cal/cm}^2$, 2nd degree burn threshold
 - Minimum required to work on live voltages: Natural fiber (cotton, wool, rayon) clothes
 - Long sleeves required to reach into battery/electrical cabinets

minimum required
 1.2 cal/cm^2



Arc Flash PPE Cat 1
 4 cal/cm^2



Arc Flash PPE Cat 2
 8 cal/cm^2




Cat 3 = 25 cal/cm^2
Cat 4 = 40 cal/cm^2



- Arc Flash PPE Category (was HRC) 1: 4 cal/cm^2 , ATPV (Arc Thermal Performance Value)
- Arc Flash PPE Category 2: 8 cal/cm^2
 - PPE Category “2+”: 12 cal/cm^2
- Arc Flash PPE Category 3: 25 cal/cm^2
- Arc Flash PPE Category 4: 40 cal/cm^2

helmet/shield good to
 12 cal/cm^2 , – can be used with
 12 cal/cm^2 clothing/coverall

Another Way of Looking at Electrical Safety



DC Arc-Flash Risk Analysis

- NFPA 70E Allows Arc-Flash Analysis by Tables in Article 130 or by Annex D.5 Calculations (see Next Pages), but Not Both to try to Get the “Best” Result

Nominal DC Voltage	Fault Current	Arc-Flash Boundary	Risk Category
0 - 100V	Any	N/A	N/A
100 - 250V	<4 kA	3'	2 - (8 cal/cm ²)
	≥4 kA and <7 kA	4'	2 - (8 cal/cm ²)
	≥7 kA and <15 kA	6'	3 - (25 cal/cm ²)
250 - 600V	<1.5 kA	3'	2 - (8 cal/cm ²)
	≥1.5 kA and <3 kA	4'	2 - (8 cal/cm ²)
	≥3 kA and <7 kA	6'	3 - (25 cal/cm ²)
	≥7 kA and <10 kA	8'	4 - (40 cal/cm ²)

This will be going up to 150 V in NFPA 70E-2024


How DC Arc-Flash cal/cm² is Calculated per NFPA 70E, and BPA & Hydro Quebec Studies

- Formula from NFPA 70E: $E_{i-m} = 0.01 \times V_{nom} \times \frac{I_{sc}}{2} \times \frac{t_{arc}}{d^2}$
 - d is usually defined as 18", but in cm (45.72)
 - Based on NFPA 70E, + BPA & Hydro Quebec studies, max t_{arc} =
 - 0.025 s for most breakers (unless known otherwise), when applicable
 - $0.326 \text{ s} \leq 100 \text{ V}_{dc}$
 - $100 \text{ V}_{dc} < 0.715 \text{ s} < 150 \text{ V}_{dc}$
 - $150 \text{ V}_{dc} \leq 1.37 \text{ s} < 270 \text{ V}_{dc}$
 - $\geq 270 \text{ V}_{dc} = 2 \text{ seconds}$
 - Simplifying the Equation: $E_{i-m} = 0.000002392 \times V_{nom} \times I_{sc} \times t_{arc}$



How Arc-Flash Boundary is Calculated per NFPA 70E, and BPA & Hydro Quebec Studies

- Algebraically Rework Formula:
$$d(\text{cm}) = \sqrt{\frac{0.01 \times V_{nom} \times I_{sc} \times t_{arc}}{2 \times E_{i-m}}}$$
 - The incident Energy (E_{i-m}) to set the arc-flash boundary is 1.2 cal/cm²
 - Based on NFPA 70E, + BPA & Hydro Quebec studies, max t_{arc} =
 - 0.025 s for most breakers (unless known otherwise), when applicable
 - $0.326 \text{ s} \leq 100 \text{ V}_{dc}$
 - $100 \text{ V}_{dc} < 0.715 \text{ s} < 150 \text{ V}_{dc}$
 - $150 \text{ V}_{dc} \leq 1.37 \text{ s} < 270 \text{ V}_{dc}$
 - $\geq 270 \text{ V}_{dc} = 2 \text{ seconds}$
 - Simplifying the Equation:
$$d(\text{in}) = \sqrt{0.0006458 \times V_{nom} \times I_{sc} \times t_{arc}}$$



Sample DC Arc-Flash Max Power Method Calculations

Battery Model	VDC	Cat	Arc-Flash Boundary	Short Circuit Amps	cal/cm ² @ 18"
MCTII-4000	2	N/A	3	26,653	0.04
	24		12		0.5
	48		16		1.0
KCR-15	2	1	2	7,407	0.01
	120		20		1.5
HR5500ET	12	N/A	3	4,786	0.04
	120		16		1.0
	240	1	32		3.8
	480	2+	54		11.0
AVR125-33	2	N/A	2	11,131	0.02
	48		11		0.4
	120	1	25		2.3
	240	2+	49		8.8
	480	4	83		25.6



Kinectrics 2007 Bruce Power Study



- Report No. K-012623-RA-0002-R00
- 125 and 260 VDC Systems
- Incident Energy Measured at Various Distances, but not 18”
- Showed Max Power Method Seriously Overestimated Incident Energy

BPA Study



Bonneville
POWER ADMINISTRATION

- IEEE PES General Meeting 2018, paper 8586181
- 1,300 Ah nominal 125 VDC (133 V Float) Lead-Acid Battery
 - Listed Bolted Fault Short Circuit Current of 11,000 A
- 60 Tests
- Maximum Arc Flash Sustain Time was 0.715 seconds
 - Ranged from 0.004 s up to 0.715 seconds
- Maximum Arc Flash Energy was 0.9 cal/cm² at 18”
 - Ranged from unmeasurable low up to 0.9
 - Below 1.2 cal/cm² Level Where Special Clothing Required
 - NFPA 70E Annex D.5 Max Power Method Predicted 10.3 cal/cm²
- Measured Max Arc Fault Current Ranged from 1,923-7,850 A

Hydro Quebec First Study



- IEEE IAS 2020 Electrical Safety Workshop (ESW), paper 14
- 69 Tests, both “Arc in a Box” and Open Air, at 105, 144, 260, and 520 VDC

V_{nom} (V)	V_{arc} (V)	I_{sc} (A)	$I_{arc-peak}$ (A)	t (s)	18" $E_{measured}$ (cal/cm ²)	18" $E_{Ammerman}$ -iterative (cal/cm ²)	18" E_{Doan-} MaxPower-2s (cal/cm ²)	18" $E_{MaxPower-}$ tvary (cal/cm ²)
105	59-65	7,000	2,900-4,000	0.04-0.33	0.02-0.24	0.8	3.5	0.6
144	78-124	17,000	900-8,000	0.02-0.49	0.005-1.7	3.0	11.7	4.2
260	112-132	20,000	8,600-10,900	0.75-1.37	6.0-10.7	12.0	24.9	17.0
520	181-184	20,000	11,000	2+	39.0-44.0	45	49.8	49.8

What's Next?



- NFPA 70E-2027 to have New Formula/Method for DC Arc Flash Calculation Based on the Testing Shown in the Previous Two Slides; + 2022 Additional Testing done by Hydro Quebec (to be published in 2023 for IEEE IAS ESW), and 2022 Testing done by C&C Power on a UPS Battery Cabinet (to be published in 2023 for Battcon)
- IEEE 1584 Will Get Upgraded in the Next Edition with the Same Types of Calculations
- Both of These Changes Will Allow Canned Arc-Flash Programs (like ETAP, etc.) to Greatly Improve Their DC Arc Flash Portions